



Addendum #1

South Street – Reading Ave to Broad Street

Bid Opening – April 28, 2026 at 2:30pm (Local Time)

Clarification – HMA Application Table on Sheet C8 of the plans was not updated to the correct HMA Mixes. . The HMA Application Table should read.

Base	3EMH	220 lbs/syd	PG 58-28
Leveling	4EMH	165 lbs/syd	PG 58-28
Top	4EMH	165 lbs/syd	PG 58-28

The Bid Form has the correct HMA Mixes Shown